## SIEMENS

## Data sheet

## 6ES7414-2XK05-0AB0



\*\*\*\*\*\*\*\*\* Replacement part \*\*\*\*\*\*\*\* SIMATIC S7-400, CPU 414-2 Central processing unit with: work memory 1 MB, (0.5 MB code, 0.5 MB data), 1st interface MPI/DP 12 Mbit/s, 2nd interface PROFIBUS DP

Figure similar

Constal information		
General information		
Product type designation	CPU 414-2	
HW functional status	03	
Firmware version	V5.3	
Product function		
Isochronous mode	Yes; For PROFIBUS only	
Engineering with		
Programming package	STEP 7 V5.3 SP2 or higher with HW update	
CiR - Configuration in RUN		
CiR synchronization time, basic load	100 ms	
CiR synchronization time, time per I/O byte	15 µs	
Supply voltage		
Rated value (DC)	Power supply via system power supply	
Input current		
from backplane bus 5 V DC, typ.	0.9 A	
from backplane bus 5 V DC, max.	1.1 A	
from backplane bus 24 V DC, max.	300 mA; 150 mA per DP interface	
from interface 5 V DC, max.	90 mA; At each DP interface	
Power loss		
Power loss, typ.	4.5 W	
Power loss, max.	5 W	
Memory		
Type of memory	RAM	
Work memory		
<ul> <li>integrated</li> </ul>	1 Mbyte	
<ul> <li>integrated (for program)</li> </ul>	0.5 Mbyte	
<ul> <li>integrated (for data)</li> </ul>	0.5 Mbyte	
• expandable	No	
Load memory		
expandable FEPROM	Yes; with Memory Card (FLASH)	
• expandable FEPROM, max.	64 Mbyte	
<ul> <li>integrated RAM, max.</li> </ul>	512 kbyte	
expandable RAM	Yes; with Memory Card (RAM)	
• expandable RAM, max.	64 Mbyte	
Backup		
• present	Yes	
• with battery	Yes; all data	
without battery	No	
Battery		

Backup battery			
<ul> <li>Backup current, typ.</li> </ul>	125 µA; up to 40 °C		
Backup current, max.	550 µA		
<ul> <li>Backup time, max.</li> </ul>	See reference manual, module data, Chapter 3.3		
<ul> <li>Feeding of external backup voltage to CPU</li> </ul>	5 V DC to 15 V DC		
CPU processing times			
for bit operations, typ.	45 ns		
for word operations, typ.	45 ns		
for fixed point arithmetic, typ.	45 ns		
for floating point arithmetic, typ.	135 ns		
CPU-blocks			
DB			
<ul> <li>Number, max.</li> </ul>	6 000; Number range: 1 to 16000		
• Size, max.	64 kbyte		
FB			
<ul> <li>Number, max.</li> </ul>	3 000; Number range: 0 to 7999		
• Size, max.	64 kbyte		
FC			
Number, max.	3 000; Number range: 0 to 7999		
• Size, max.	64 kbyte		
OB			
Number, max.	see instruction list		
• Size, max.	64 kbyte		
Number of free cycle OBs	1; OB 1		
Number of time alarm OBs	4; OB 10-13		
Number of delay alarm OBs	4; OB 20-23		
Number of cyclic interrupt OBs	4; OB 32-35 (shortest cycle that can be set = 500 $\mu$ s)		
Number of process alarm OBs	4; OB 40-43		
Number of DPV1 alarm OBs	4, OB 40-43 3; OB 55-57		
Number of isochronous mode OBs			
	3; OB 61-63		
Number of multicomputing OBs	1; OB 60		
Number of background OBs	1; OB 90		
Number of startup OBs	3; OB 100-102		
Number of asynchronous error OBs	9; OB 80-88		
Number of synchronous error OBs	2; OB 121, 122		
Nesting depth	24		
• per priority class	24		
<ul> <li>additional within an error OB</li> </ul>	1		
Counters, timers and their retentivity			
S7 counter			
Number	2 048		
Retentivity			
— adjustable	Yes		
— preset	Z 0 to Z 7		
Counting range			
— lower limit	0		
— upper limit	999		
IEC counter			
present	Yes		
• Туре	SFB		
Number	Unlimited (limited only by RAM capacity)		
S7 times			
Number	2 048		
Retentivity			
— adjustable	Yes		
— preset	No times retentive		
Time range			
— lower limit	10 ms		
— upper limit	9 990 s		
IEC timer			

• present	Yes	
• Туре	SFB	
Number	Unlimited (limited only by RAM capacity)	
Data areas and their retentivity		
Retentive data area (incl. timers, counters, flags), max.	Total working and load memory (with backup battery)	
Flag		
• Size, max.	8 kbyte; Size of bit memory address area	
Retentivity available	Yes	
Retentivity preset	MB 0 to MB 15	
Number of clock memories	8; in 1 memory byte	
Local data		
<ul> <li>adjustable, max.</li> </ul>	16 kbyte	
• preset	8 kbyte	
Address area		
I/O address area		
Inputs	8 kbyte	
Outputs	8 kbyte	
Process image		
<ul> <li>Inputs, adjustable</li> </ul>	8 kbyte	
<ul> <li>Outputs, adjustable</li> </ul>	8 kbyte	
<ul> <li>Inputs, default</li> </ul>	256 byte	
<ul> <li>Outputs, default</li> </ul>	256 byte	
<ul> <li>consistent data, max.</li> </ul>	244 byte	
<ul> <li>Access to consistent data in process image</li> </ul>	Yes	
Subprocess images		
<ul> <li>Number of subprocess images, max.</li> </ul>	15	
Digital channels		
Inputs	65 536	
— of which central	65 536	
Outputs	65 536	
— of which central	65 536	
Analog channels		
Inputs	4 096	
— of which central	4 096	
Outputs	4 096	
— of which central	4 096	
Hardware configuration		
Integrated power supply	No	
Number of expansion units, max.	21	
connectable OPs	31	
Multicomputing	Yes; 4 CPUs max. (with UR1 or UR2)	
Interface modules		
Number of connectable IMs (total), max.	6	
Number of connectable IM 460s, max.	6	
Number of connectable IM 463s, max.	4; IM 463-2	
Number of DP masters		
• integrated	2	
• via CP	10; CP 443-5 Extended	
• via IM 467	4	
Mixed mode IM + CP permitted	No; IM 467 not suitable for use with CP 443-5 Ext. and CP 443-1 EX4x, EX20, GX20 (in PROFINET IO mode)	
• via interface module	0	
<ul> <li>Number of pluggable S5 modules (via adapter capsule in central device), max.</li> </ul>	6	
Number of IO Controllers		
• integrated	0	
• via CP	4; No mixed operation of CP443-1 EX40 and CP443-1 EX 41/EX20/GX20,	
	max. 4 in central controller	
Number of operable FMs and CPs (recommended)		
• FM	Limited by number of slots and number of connections	
• CP, PtP	CP 440: Limited by number of slots; CP 441: limited by number of connections	

PROFIBUS and Ethernet CPs

14; Of which 10 CPs max. or IMs as DP master, 4 PROFINET controller maximum

Slots	maximum
required slots	1
Time of day	
Clock	Yes
Hardware clock (real-time)	Yes
<ul> <li>retentive and synchronizable</li> <li>Resolution</li> </ul>	res 1 ms
Deviation per day (buffered), max.     Deviation per day (unbuffered), may	1.7 s; Power off 8.6 s: For power On
Deviation per day (unbuffered), max. Operating hours counter	8.6 s; For power On
Number	16
Number/Number range	0 to 15
Range of values	SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours
	1 h
Granularity     retentive	Yes
Clock synchronization	
supported	Yes
to MPI, master	Yes
• to MPI, master • to MPI, slave	Yes
• to DP, master	Yes
• to DP, slave	Yes
<ul> <li>in AS, master</li> </ul>	Yes
• in AS, slave	Yes
on Ethernet via NTP	No; Via CP
Time difference in system when synchronizing via	
MPI, max.	200 ms
• MP1, max. Interfaces	
Interfaces/bus type	1 x MPI/PROFIBUS DP, 1 x PROFIBUS DP
Number of RS 485 interfaces	2; Combined MPI / PROFIBUS DP and PROFIBUS DP No
Optical interface	INU
-	
1. Interface	
1. Interface Interface type	MPI/PROFIBUS DP
1. Interface Interface type Isolated	
1. Interface Interface type Isolated Interface types	MPI/PROFIBUS DP Yes
1. Interface Interface type Isolated Interface types • RS 485	MPI/PROFIBUS DP Yes Yes
1. Interface Interface type Isolated Interface types • RS 485 • Output current of the interface, max.	MPI/PROFIBUS DP Yes
1. Interface         Interface type         Isolated         Interface types         • RS 485         • Output current of the interface, max.         Protocols	MPI/PROFIBUS DP Yes Yes 150 mA
1. Interface Interface type Isolated Interface types • RS 485 • Output current of the interface, max. Protocols • MPI	MPI/PROFIBUS DP Yes Yes 150 mA Yes
1. Interface Interface type Isolated Interface types • RS 485 • Output current of the interface, max. Protocols • MPI • PROFIBUS DP master	MPI/PROFIBUS DP Yes Yes 150 mA Yes Yes
1. Interface Interface type Isolated Interface types • RS 485 • Output current of the interface, max. Protocols • MPI • PROFIBUS DP master • PROFIBUS DP slave	MPI/PROFIBUS DP Yes Yes 150 mA Yes
1. Interface Interface type Isolated Interface types • RS 485 • Output current of the interface, max. Protocols • MPI • PROFIBUS DP master	MPI/PROFIBUS DP Yes Yes 150 mA Yes Yes
1. Interface Interface type Isolated Interface types • RS 485 • Output current of the interface, max. Protocols • MPI • PROFIBUS DP master • PROFIBUS DP slave MPI	MPI/PROFIBUS DP Yes Yes 150 mA Yes Yes Yes 32; If a diagnostics repeater is used on the line, the number of connection
1. Interface Interface type Isolated Interface types • RS 485 • Output current of the interface, max. Protocols • MPI • PROFIBUS DP master • PROFIBUS DP slave MPI • Number of connections	MPI/PROFIBUS DP Yes Yes 150 mA Yes Yes Yes Yes Yes
1. Interface         Interface type         Isolated         Interface types         • RS 485         • Output current of the interface, max.         Protocols         • MPI         • PROFIBUS DP master         • PROFIBUS DP slave         MPI         • Number of connections         • Transmission rate, max.	MPI/PROFIBUS DP Yes Yes 150 mA Yes Yes Yes Yes Yes
1. Interface         Interface type         Isolated         Interface types         • RS 485         • Output current of the interface, max.         Protocols         • MPI         • PROFIBUS DP master         • PROFIBUS DP slave         MPI         • Number of connections         • Transmission rate, max.         Services	MPI/PROFIBUS DP Yes Yes Yes Yes Yes Yes Yes 32; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s
1. Interface Interface type Isolated Interface types • RS 485 • Output current of the interface, max. Protocols • MPI • PROFIBUS DP master • PROFIBUS DP slave MPI • Number of connections • Transmission rate, max. Services — PG/OP communication	MPI/PROFIBUS DP Yes Yes 150 mA Yes Yes Yes Yes 32; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s Yes
Interface     Interface type     Isolated     Interface types         RS 485         Output current of the interface, max.     Protocols         MPI         PROFIBUS DP master         PROFIBUS DP slave     MPI         Number of connections         Transmission rate, max.     Services         — PG/OP communication         — Routing	MPI/PROFIBUS DP Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
1. Interface         Interface type         Isolated         Interface types         • RS 485         • Output current of the interface, max.         Protocols         • MPI         • PROFIBUS DP master         • PROFIBUS DP slave         MPI         • Number of connections         • Transmission rate, max.         Services         — PG/OP communication         — Routing         — Global data communication	MPI/PROFIBUS DP Yes Yes 150 mA Yes Yes Yes Yes 32; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s Yes Yes Yes Yes
1. Interface         Interface type         Isolated         Interface types         • RS 485         • Output current of the interface, max.         Protocols         • MPI         • PROFIBUS DP master         • PROFIBUS DP slave         MPI         • Number of connections         • Transmission rate, max.         Services         — PG/OP communication         — Routing         — Global data communication         — S7 basic communication	MPI/PROFIBUS DP Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
1. Interface         Interface type         Isolated         Interface types         • RS 485         • Output current of the interface, max.         Protocols         • MPI         • PROFIBUS DP master         • PROFIBUS DP slave         MPI         • Number of connections         • Transmission rate, max.         Services         — PG/OP communication         — Routing         — Global data communication         — S7 basic communication         — S7 communication	MPI/PROFIBUS DP Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
1. Interface         Interface type         Isolated         Interface types         • RS 485         • Output current of the interface, max.         Protocols         • MPI         • PROFIBUS DP master         • PROFIBUS DP slave         MPI         • Number of connections         • Transmission rate, max.         Services         — PG/OP communication         — Routing         — Global data communication         — S7 basic communication         — S7 communication         — S7 communication, as client	MPI/PROFIBUS DP Yes Yes 150 mA Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
1. Interface         Interface type         Isolated         Interface types         • RS 485         • Output current of the interface, max.         Protocols         • MPI         • PROFIBUS DP master         • PROFIBUS DP slave         MPI         • Number of connections         • Transmission rate, max.         Services         — PG/OP communication         — Routing         — Global data communication         — S7 communication         — S7 communication, as client         — S7 communication, as server	MPI/PROFIBUS DP Yes Yes 150 mA Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
1. Interface         Interface type         Isolated         Interface types         • RS 485         • Output current of the interface, max.         Protocols         • MPI         • PROFIBUS DP master         • PROFIBUS DP slave         MPI         • Number of connections         • Transmission rate, max.         Services         — PG/OP communication         — Routing         — Global data communication         — S7 communication         — S7 communication, as client         — S7 communication, as server         PROFIBUS DP master	MPI/PROFIBUS DP Yes Yes Yes 150 mA Yes Yes Yes 32; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
1. Interface         Interface type         Isolated         Interface types         • RS 485         • Output current of the interface, max.         Protocols         • MPI         • PROFIBUS DP master         • PROFIBUS DP slave         MPI         • Number of connections         • Transmission rate, max.         Services         — PG/OP communication         — Routing         — Global data communication         — S7 basic communication         — S7 communication         — S7 communication, as client         — S7 communication, as server	MPI/PROFIBUS DP Yes Yes 150 mA Yes Yes Yes Yes 32; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
1. Interface         Interface type         Isolated         Interface types         • RS 485         • Output current of the interface, max.         Protocols         • MPI         • PROFIBUS DP master         • PROFIBUS DP slave         MPI         • Number of connections         • Transmission rate, max.         Services         — PG/OP communication         — Routing         — Global data communication         — S7 communication         — S7 communication         — S7 communication, as client         — S7 communication, as server         PROFIBUS DP master         • Number of connections, max.         • Transmission rate, max.	MPI/PROFIBUS DP Yes Yes 150 mA Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes
1. Interface         Interface type         Isolated         Interface types         • RS 485         • Output current of the interface, max.         Protocols         • MPI         • PROFIBUS DP master         • PROFIBUS DP slave         MPI         • Number of connections         • Transmission rate, max.         Services         — PG/OP communication         — Routing         — Global data communication         — S7 basic communication         — S7 communication         — S7 communication, as client         — S7 communication, as server         PROFIBUS DP master         • Number of connections, max.         • Transmission rate, max.         • Number of connections, max.	MPI/PROFIBUS DP Yes Yes Yes 150 mA Yes Yes Yes Yes 32; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 12 Mbit/s Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye

Deutier	Ver 07 multi-		
- Routing	Yes; S7 routing		
— Global data communication	No		
— S7 basic communication	Yes		
— S7 communication	Yes		
— S7 communication, as client	Yes		
— S7 communication, as server	Yes		
— Equidistance	Yes		
— Isochronous mode	Yes		
— SYNC/FREEZE	Yes		
<ul> <li>Activation/deactivation of DP slaves</li> </ul>	Yes		
— Direct data exchange (slave-to-slave communication)	Yes		
— DPV1	Yes		
Address area			
— Inputs, max.	2 kbyte		
— Outputs, max.	2 kbyte		
User data per DP slave			
— User data per DP slave, max.	244 byte		
— Inputs, max.	244 byte		
— Outputs, max.	244 byte		
— Slots, max.	244		
— per slot, max.	128 byte		
PROFIBUS DP slave			
Number of connections	16		
• GSD file	http://support.automation.siemens.com/WW/view/en/113652		
<ul> <li>Transmission rate, max.</li> </ul>	12 Mbit/s		
<ul> <li>automatic baud rate search</li> </ul>	No		
<ul> <li>Address area, max.</li> </ul>	32; Virtual slots		
<ul> <li>User data per address area, max.</li> </ul>	32 byte		
- of which consistent, max.	32 byte		
Services			
— PG/OP communication	Yes; with interface active		
— Routing	Yes; with interface active		
— Global data communication	No		
— S7 basic communication	No		
— S7 communication	Yes		
- S7 communication, as client	Yes		
— S7 communication, as server	Yes		
— Direct data exchange (slave-to-slave	No		
communication)			
— DPV1	No		
Transfer memory			
— Inputs	244 byte		
— Outputs	244 byte		
2. Interface			
Interface type	PROFIBUS DP		
Isolated	Yes		
Interface types			
• RS 485	Yes		
<ul> <li>Output current of the interface, max.</li> </ul>	150 mA		
Protocols			
PROFIBUS DP master	Yes		
PROFIBUS DP slave	Yes		
PROFIBUS DP master			
<ul> <li>Number of connections, max.</li> </ul>	16		
• Transmission rate, max.	12 Mbit/s		
Number of DP slaves, max.	96		
Services			
— PG/OP communication	Yes		
<ul> <li>— PG/OP communication</li> <li>— Routing</li> </ul>	Yes Yes: S7 routing		
<ul> <li>— PG/OP communication</li> <li>— Routing</li> <li>— Global data communication</li> </ul>	Yes; S7 routing No		

C7 hosis communication	Vee	
- S7 basic communication	Yes	
— S7 communication	Yes	
— S7 communication, as client	Yes	
— S7 communication, as server	Yes	
— Equidistance	Yes	
— Isochronous mode		
- SYNC/FREEZE	Yes	
<ul> <li>Activation/deactivation of DP slaves</li> </ul>	Yes	
<ul> <li>— Direct data exchange (slave-to-slave communication)</li> </ul>	Yes	
— DPV1	Yes	
Address area		
— Inputs, max.	6 kbyte	
— Outputs, max.	6 kbyte	
User data per DP slave		
— User data per DP slave, max.	244 byte	
— Inputs, max.	244 byte	
— Outputs, max.	244 byte	
— Slots, max.	244	
— per slot, max.	128 byte	
PROFIBUS DP slave		
Number of connections	16	
GSD file	http://support.automation.siemens.com/WW/view/en/113652	
<ul> <li>Transmission rate, max.</li> </ul>	12 Mbit/s	
<ul> <li>Address area, max.</li> </ul>	32	
<ul> <li>User data per address area, max.</li> </ul>	32 byte	
— of which consistent, max.	32 byte	
Services		
— Routing	Yes	
Transfer memory		
	044 h. 4	
— Inputs	244 byte	
— Inputs — Outputs	244 byte	
— Outputs		
- Outputs Protocols		
— Outputs Protocols SIMATIC communication	244 byte	
- Outputs Protocols SIMATIC communication • S7 routing	244 byte	
- Outputs Protocols SIMATIC communication • S7 routing Open IE communication	244 byte Yes	
Outputs Protocols SIMATIC communication • S7 routing Open IE communication • ISO-on-TCP (RFC1006)	244 byte Yes Via CP 443-1 and loadable FB	
— Outputs  Protocols  SIMATIC communication      • S7 routing  Open IE communication      • ISO-on-TCP (RFC1006)      — Data length, max.  Web server	244 byte Yes Via CP 443-1 and loadable FB	
Outputs  Protocols  SIMATIC communication  • S7 routing  Open IE communication  • ISO-on-TCP (RFC1006)  Data length, max.  Web server  • supported	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv.	
Outputs Protocols SIMATIC communication • S7 routing Open IE communication • ISO-on-TCP (RFC1006) Data length, max. Web server • supported Isochronous mode	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv.	
Outputs  Protocols  SIMATIC communication  • S7 routing  Open IE communication  • ISO-on-TCP (RFC1006)  Data length, max.  Web server  • supported	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No	
Outputs Protocols SIMATIC communication • S7 routing Open IE communication • ISO-on-TCP (RFC1006) Data length, max. Web server • supported Isochronous mode Equidistance	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2	
— Outputs  Protocols  SIMATIC communication      • S7 routing  Open IE communication      • ISO-on-TCP (RFC1006)      — Data length, max.  Web server      • supported  Isochronous mode  Equidistance  Number of DP masters with isochronous mode User data per isochronous slave, max.	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes	
— Outputs      Protocols      SIMATIC communication     • S7 routing      Open IE communication     • ISO-on-TCP (RFC1006)         — Data length, max.      Web server     • supported      Isochronous mode      Equidistance      Number of DP masters with isochronous mode      User data per isochronous slave, max.     shortest clock pulse	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte	
Outputs      Protocols      SIMATIC communication         • S7 routing      Open IE communication         • ISO-on-TCP (RFC1006)             — Data length, max.      Web server         • supported      Isochronous mode      Equidistance      Number of DP masters with isochronous mode      User data per isochronous slave, max.     shortest clock pulse     max. cycle	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127	
Outputs      Protocols      SIMATIC communication         • S7 routing      Open IE communication         • ISO-on-TCP (RFC1006)	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127 32 ms	
— Outputs      Protocols      SIMATIC communication         • S7 routing      Open IE communication         • ISO-on-TCP (RFC1006)	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127 32 ms	
Outputs      Protocols      SIMATIC communication         • S7 routing      Open IE communication         • ISO-on-TCP (RFC1006)            Data length, max.      Web server         • supported      Isochronous mode      Equidistance      Number of DP masters with isochronous mode      User data per isochronous slave, max.     shortest clock pulse     max. cycle      Communication     • Number of connectable OPs without message processing	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127 32 ms Yes 31	
Outputs  Protocols  SIMATIC communication  • S7 routing  Open IE communication  • ISO-on-TCP (RFC1006)  Data length, max.  Web server  • supported  Isochronous mode  Equidistance  Number of DP masters with isochronous mode  User data per isochronous slave, max. shortest clock pulse max. cycle  communication functions / header  PG/OP communication  • Number of connectable OPs without message processing • Number of connectable OPs with message processing	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127 32 ms Yes 31 31; When using Alarm_S/SQ and Alarm_D/DQ	
Outputs Protocols SIMATIC communication • S7 routing Open IE communication • ISO-on-TCP (RFC1006) Data length, max. Web server • supported Isochronous mode Equidistance Number of DP masters with isochronous mode User data per isochronous slave, max. shortest clock pulse max. cycle Communication functions / header PG/OP communication • Number of connectable OPs without message processing • Number of connectable OPs with message processing	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127 32 ms Yes 31	
Outputs  Protocols  SIMATIC communication  • S7 routing  Open IE communication  • ISO-on-TCP (RFC1006)  Data length, max.  Web server  • supported  Isochronous mode  Equidistance  Number of DP masters with isochronous mode  User data per isochronous slave, max. shortest clock pulse max. cycle  Communication functions / header  PG/OP communication  • Number of connectable OPs without message processing • Number of connectable OPs with message processing Data record routing Global data communication	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127 32 ms Yes 31 31; When using Alarm_S/SQ and Alarm_D/DQ Yes	
Outputs  Protocols  SIMATIC communication  • S7 routing  Open IE communication  • ISO-on-TCP (RFC1006)  Data length, max.  Web server  • supported  Isochronous mode  Equidistance  Number of DP masters with isochronous mode  User data per isochronous slave, max. shortest clock pulse max. cycle  Communication functions / header  PG/OP communication  • Number of connectable OPs without message processing Data record routing  Global data communication  • supported	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127 32 ms Yes 31 31; When using Alarm_S/SQ and Alarm_D/DQ Yes	
Outputs  Protocols  SIMATIC communication  S7 routing Open IE communication  ISO-on-TCP (RFC1006)  Data length, max. Web server  supported  Isochronous mode  Equidistance Number of DP masters with isochronous mode User data per isochronous slave, max. shortest clock pulse max. cycle  communication functions / header  PG/OP communication  Number of connectable OPs without message processing Data record routing Global data communication  supported  Number of GD loops, max.	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127 32 ms Yes 31 31; When using Alarm_S/SQ and Alarm_D/DQ Yes 8	
<ul> <li>Outputs</li> <li>Protocols</li> <li>SIMATIC communication         <ul> <li>S7 routing</li> <li>Open IE communication</li> <li>ISO-on-TCP (RFC1006)</li></ul></li></ul>	244 byte Yes Yia CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127 32 ms Yes 31 31; When using Alarm_S/SQ and Alarm_D/DQ Yes 8 8	
Outputs Protocols SIMATIC communication • S7 routing Open IE communication • ISO-on-TCP (RFC1006) Data length, max. Web server • supported Isochronous mode Equidistance Number of DP masters with isochronous mode User data per isochronous slave, max. shortest clock pulse max. cycle Communication • Number of connectable OPs without message processing • Number of connectable OPs with message processing Data record routing Global data communication • supported • Number of GD loops, max. • Number of GD packets, transmitter, max. • Number of GD packets, receiver, max.	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127 32 ms Yes 31 31; When using Alarm_S/SQ and Alarm_D/DQ Yes 8 8 8 8 16	
<ul> <li>– Outputs</li> <li>Protocols</li> <li>SIMATIC communication <ul> <li>S7 routing</li> </ul> </li> <li>Open IE communication <ul> <li>ISO-on-TCP (RFC1006)</li> <li>– Data length, max.</li> </ul> </li> <li>Web server <ul> <li>supported</li> </ul> </li> <li>Isochronous mode</li> <li>Equidistance</li> <li>Number of DP masters with isochronous mode</li> <li>User data per isochronous slave, max.</li> <li>shortest clock pulse max. cycle</li> </ul> <li>Communication <ul> <li>Number of connectable OPs without message processing</li> <li>Number of connectable OPs with message processing</li> <li>Data record routing</li> </ul> </li> <li>Global data communication <ul> <li>supported</li> <li>Number of GD packets, transmitter, max.</li> <li>Number of GD packets, receiver, max.</li> <li>Size of GD packets, max.</li> </ul> </li>	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127 32 ms Yes 31 31; When using Alarm_S/SQ and Alarm_D/DQ Yes 9 Yes 8 8 8 8 16 54 byte	
<ul> <li>– Outputs</li> <li>Protocols</li> <li>SIMATIC communication <ul> <li>S7 routing</li> </ul> </li> <li>Open IE communication <ul> <li>ISO-on-TCP (RFC1006)</li> <li>– Data length, max.</li> </ul> </li> <li>Web server <ul> <li>supported</li> </ul> </li> <li>Isochronous mode</li> <li>Equidistance</li> <li>Number of DP masters with isochronous mode</li> <li>User data per isochronous slave, max.</li> <li>shortest clock pulse <ul> <li>max. cycle</li> </ul> </li> <li>Communication <ul> <li>Number of connectable OPs without message processing</li> <li>Number of connectable OPs with message processing</li> </ul> </li> <li>Data record routing</li> <li>Global data communication <ul> <li>supported</li> <li>Number of GD packets, transmitter, max.</li> <li>Number of GD packets, max.</li> <li>Size of GD packets, max.</li> <li>Size of GD packet (of which consistent), max.</li> </ul> </li> </ul>	244 byte Yes Via CP 443-1 and loadable FB 1 452 bytes via CP 443-1 Adv. No Yes 2 244 byte 1 ms; 0.5 ms without use of SFC 126, 127 32 ms Yes 31 31; When using Alarm_S/SQ and Alarm_D/DQ Yes 8 8 8 8 16	
	244 byte         Yes         Via CP 443-1 and loadable FB         1 452 bytes via CP 443-1 Adv.         No         Yes         2         244 byte         1 ms; 0.5 ms without use of SFC 126, 127         32 ms         Yes         31         31; When using Alarm_S/SQ and Alarm_D/DQ         Yes         8         8         16         54 byte         1 variable	
<ul> <li>– Outputs</li> <li>Protocols</li> <li>SIMATIC communication <ul> <li>S7 routing</li> </ul> </li> <li>Open IE communication <ul> <li>ISO-on-TCP (RFC1006)</li> <li>– Data length, max.</li> </ul> </li> <li>Web server <ul> <li>supported</li> </ul> </li> <li>Isochronous mode</li> <li>Equidistance</li> <li>Number of DP masters with isochronous mode</li> <li>User data per isochronous slave, max.</li> <li>shortest clock pulse <ul> <li>max. cycle</li> </ul> </li> <li>Communication <ul> <li>Number of connectable OPs without message processing</li> <li>Number of connectable OPs with message processing</li> </ul> </li> <li>Data record routing</li> <li>Global data communication <ul> <li>supported</li> <li>Number of GD packets, transmitter, max.</li> <li>Number of GD packets, max.</li> <li>Size of GD packets, max.</li> <li>Size of GD packet (of which consistent), max.</li> </ul> </li> </ul>	244 byte         Yes         Via CP 443-1 and loadable FB         1 452 bytes via CP 443-1 Adv.         No         Yes         2         244 byte         1 ms; 0.5 ms without use of SFC 126, 127         32 ms         Yes         31         31; When using Alarm_S/SQ and Alarm_D/DQ         Yes         8         8         16         54 byte	

a Lloor data par ich (of which consistent) may	1 variable		
User data per job (of which consistent), max.	i vanabie		
S7 communication	N/		
supported	Yes		
• as server	Yes		
• as client	Yes		
<ul> <li>User data per job, max.</li> </ul>	64 kbyte		
<ul> <li>User data per job (of which consistent), max.</li> </ul>	462 byte; 1 variable		
S5 compatible communication			
<ul> <li>supported</li> </ul>	Yes; Via FC AG_SEND and AG_RECV, max. via 10 CP 443-1 or 443-5		
<ul> <li>User data per job, max.</li> </ul>	8 kbyte		
<ul> <li>User data per job (of which consistent), max.</li> </ul>	240 byte		
<ul> <li>Number of simultaneous AG-SEND/AG-RECV orders per CPU, max.</li> </ul>	24/24		
Standard communication (FMS)			
supported	Yes; Via CP and loadable FB		
Number of connections			
overall	32		
usable for PG communication	31		
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication</li> </ul>	1		
<ul> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> </ul>			
usable for OP communication	31		
- reserved for OP communication	1		
— adjustable for OP communication, max.	0		
usable for S7 basic communication	30		
— reserved for S7 basic communication	0		
— adjustable for S7 basic communication, max.	0		
usable for S7 communication	30		
— reserved for S7 communication	0		
— adjustable for S7 communication, max.	0		
usable for routing	15		
<ul> <li>reserved for routing</li> </ul>	0		
— adjustable for routing, max.	0		
S7 message functions			
	0 31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)		
S7 message functions	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8		
S7 message functions Number of login stations for message functions, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)		
S7 message functions Number of login stations for message functions, max. Symbol-related messages	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC) Yes		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC) Yes Yes		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC) Yes Yes Yes		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC) Yes Yes Yes Yes		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC) Yes Yes Yes Yes 400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC) Yes Yes Yes Yes 400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks Yes		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC) Yes Yes Yes 400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks Yes 1 200		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC) Yes Yes Yes 400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks Yes 1 200 300		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • process control messages         Number of archives that can log on simultaneously (SFB 37	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC) Yes Yes Yes 400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks Yes 1 200 300 Yes		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • preset, max.         Process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC) Yes Yes Yes 400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks Yes 1 200 300 Yes		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • preset, max.         Process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         Yes         Yes         Yes         Yes         Yes         Yes         Yes         Yes         300         Yes         16		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages         • overall, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         300         Yes         16         512		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages         • overall, max.         • in 100 ms grid, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         Yes         Yes         Yes         400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks         Yes         1 200         300         Yes         16         512         128		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages         • overall, max.         • in 100 ms grid, max.         • in 500 ms grid, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         Yes         Yes         Yes         400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks         Yes         1 200         300         Yes         16         512         128         256		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • preset, max.         • process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages         • overall, max.         • in 100 ms grid, max.         • in 1000 ms grid, max.         • in 1000 ms grid, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         Yes         Yes         Yes         400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks         Yes         1 200         300         Yes         16         512         128         256		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • preset, max.         Process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages         • overall, max.         • in 100 ms grid, max.         • in 1000 ms grid, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks         Yes         1 200         300         Yes         16         512         512         512         512		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • preset, max.         Process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages         • overall, max.         • in 100 ms grid, max.         • in 1000 ms grid, max.         • in 1000 ms grid, max.         • with 100 ms grid, max.         • with 100 ms grid, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks         Yes         1 200         300         Yes         16         512         128         256         512         1         1		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • preset, max.         • preset, max.         • preset, max.         • process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages         • overall, max.         • in 100 ms grid, max.         • in 100 ms grid, max.         • in 1000 ms grid, max.         • with 100 ms grid, max.         • with 100 ms grid, max.         • with 500, 1000 ms grid, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks         Yes         1 200         300         Yes         16         512         128         256         512         1         1		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • preset, max.         • process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages         • overall, max.         • in 100 ms grid, max.         • in 500 ms grid, max.         • in 1000 ms grid, max.         • with 100 ms grid, max.         • with 500, 1000 ms grid, max.         • with 500, 1000 ms grid, max.         • with 500, 1000 ms grid, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks         Yes         1 200         300         Yes         16         512         128         256         512         1         10		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • preset, max.         Process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages         • overall, max.         • in 100 ms grid, max.         • in 500 ms grid, max.         • with 100 ms grid, max.         • with 100 ms grid, max.         • with 500, 1000 ms grid, max.	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         Yes         Yes         Yes         400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks         Yes         1 200         300         Yes         512         16         512         128         256         512         1         10         Yes; Up to 2 simultaneously		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • preset, max.         • process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages         • overall, max.         • in 100 ms grid, max.         • in 500 ms grid, max.         • with 100 ms grid, max.         • with 500, 1000 ms grid, max.         • with 500, 1000 ms grid, max.         • with 500, 1000 ms grid, max.         • status block         Single step	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         Yes         Yes         Yes         400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks         Yes         1 200         300         Yes         512         128         256         512         1         10         Yes; Up to 2 simultaneously         Yes		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         • preset, max.         Process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages         • overall, max.         • in 100 ms grid, max.         • in 500 ms grid, max.         • in 100 ms grid, max.         • with 100 ms grid, max.         • with 500, 1000 ms grid, max.         • Status block         Single step         Number of breakpoints	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         Yes         Yes         Yes         400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks         Yes         1 200         300         Yes         512         128         256         512         1         10         Yes; Up to 2 simultaneously         Yes		
S7 message functions         Number of login stations for message functions, max.         Symbol-related messages         SCAN procedure         Program alarms         Process diagnostic messages         simultaneously active Alarm-S blocks, max.         Alarm 8-blocks         • Number of instances for alarm 8 and S7 communication blocks, max.         • preset, max.         Process control messages         Number of archives that can log on simultaneously (SFB 37 AR_SEND)         Number of messages         • overall, max.         • in 100 ms grid, max.         • in 500 ms grid, max.         • in 1000 ms grid, max.         • with 100 ms grid, max.         • with 500, 1000 ms grid, max.         • Status block         Single step         Number of breakpoints         Status/control	31; Max. 31 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm_8 and Alarm_P (e.g. WinCC)         Yes         Yes         Yes         Yes         400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks         Yes         1 200         300         Yes         16         512         12         12         Yes         Yes         400         Yes         400         Yes         1 200         300         Yes         16         7         Yes         16         7         Yes         1         10         Yes; Up to 2 simultaneously         Yes         4		

Subject to change without notice © Copyright Siemens

Number of variables, max.	70. Status/control		
Forcing	70; Status/control		
Forcing	Yes		
Forcing, variables			
Number of variables, max.	Inputs, outputs, bit memories, peripheral inputs, peripheral outputs 256		
Diagnostic buffer	200		
	Vac		
present     Number of entries, max	Yes 400		
Number of entries, max.			
- adjustable	Yes 120		
— preset Service data	120		
can be read out	Yes		
	Tes		
Standards, approvals, certificates	Ver		
CE mark	Yes		
CSA approval	Yes		
UL approval	Yes		
	Yes		
FM approval	Yes		
RCM (formerly C-TICK)	Yes		
KC approval	Yes		
EAC (formerly Gost-R)	Yes		
Use in hazardous areas			
• ATEX	ATEX II 3G Ex nA IIC T4 Gc		
Ambient conditions			
Ambient temperature during operation			
● min.	0 °C		
• max.	60 °C		
configuration / header			
Configuration software			
STEP 7	Yes		
configuration / programming / header			
Command set	see instruction list		
Command set     Nesting levels	7		
<ul><li>Command set</li><li>Nesting levels</li><li>Access to consistent data in process image</li></ul>	7 Yes		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> </ul>	7 Yes see instruction list		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> </ul>	7 Yes		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language</li> </ul>	7 Yes see instruction list see instruction list		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> </ul> </li> </ul>	7 Yes see instruction list see instruction list Yes		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> </ul> </li> </ul>	7 Yes see instruction list see instruction list Yes Yes		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> </ul> </li> </ul>	7 Yes see instruction list see instruction list Yes Yes Yes		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> </ul> </li> </ul>	7 Yes see instruction list see instruction list Yes Yes Yes		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> </ul> </li> </ul>	7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> </ul> </li> </ul>	7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> </ul>	7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> </ul>	7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously active</li> <li>DPSYC_FR</li> </ul>	7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Yes		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously active</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> </ul>	7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes SFC / header 2; SFC 11; per interface 8; SFC 12; per interface		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously active</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> <li>RD_REC</li> </ul>	7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes SFC / header 2; SFC 11; per interface 8; SFC 12; per interface 8; SFC 59; per interface		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously active</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> <li>RD_REC</li> <li>WR_REC</li> </ul>	7 Yes see instruction list see instruction list see instruction list Yes Yes Yes Yes Yes Yes SFC / header 2; SFC 11; per interface 8; SFC 59; per interface 8; SFC 59; per interface 8; SFC 59; per interface		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously actives</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> <li>RD_REC</li> <li>WR_REC</li> <li>WR_PARM</li> </ul>	7 Yes see instruction list see instruction list see instruction list Yes Yes Yes Yes Yes Yes SEC / header 2; SFC 11; per interface 8; SFC 29; per interface 8; SFC 59; per interface 8; SFC 58; per interface 8; SFC 55; per interface		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously actives</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> <li>RD_REC</li> <li>WR_REC</li> <li>WR_PARM</li> <li>PARM_MOD</li> </ul>	7 Yes see instruction list see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes SFC / header 2; SFC 11; per interface 8; SFC 59; per interface 8; SFC 59; per interface 8; SFC 58; per interface 8; SFC 58; per interface 1; SFC 57; per interface		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously active</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> <li>RD_REC</li> <li>WR_REC</li> <li>WR_PARM</li> <li>PARM_MOD</li> <li>WR_DPARM</li> </ul>	7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes SFC / header 2; SFC 11; per interface 8; SFC 12; per interface 8; SFC 59; per interface 8; SFC 59; per interface 8; SFC 55; per interface 1; SFC 57; per interface 2; SFC 56; per interface		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously active</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> <li>RD_REC</li> <li>WR_REC</li> <li>WR_PARM</li> <li>PARM_MOD</li> <li>WR_DPARM</li> <li>DPNRM_DG</li> </ul>	7 Yes see instruction list see instruction list see instruction list Yes Yes Yes Yes Yes SFC / header 2; SFC 11; per interface 8; SFC 59; per interface 8; SFC 59; per interface 8; SFC 59; per interface 8; SFC 59; per interface 8; SFC 50; per interface		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously active</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> <li>RD_REC</li> <li>WR_REC</li> <li>WR_PARM</li> <li>PARM_MOD</li> <li>WR_DPARM</li> <li>DPNRM_DG</li> <li>RDSYSST</li> </ul>	7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes SFC / header 2; SFC 11; per interface 8; SFC 59; per interface 8; SFC 59; per interface 8; SFC 59; per interface 8; SFC 59; per interface 8; SFC 56; per interface 8; SFC 56; per interface 8; SFC 57; per interface 8; SFC 56; per interface 8; SFC 57; per interface 8; SFC 57; per interface 8; SFC 56; per interface 8; SFC 13; per interface 8; SFC 13; per interface 8; SFC 13; per interface 8; SFC 13; per interface		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously active</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> <li>RD_REC</li> <li>WR_REC</li> <li>WR_PARM</li> <li>PARM_MOD</li> <li>WR_DPARM</li> <li>DPNRM_DG</li> <li>RDSYSST</li> <li>DP_TOPOL</li> </ul>	7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes SEC / header 2; SFC 11; per interface 8; SFC 12; per interface 8; SFC 59; per interface 8; SFC 59; per interface 8; SFC 55; per interface 8; SFC 56; per interface 8; SFC 56; per interface 8; SFC 57; per interface 8; SFC 56; per interface 8; SFC 57; per interface 8; SFC 13; per interface 8; SFC 13; per interface 8 1; SFC 103; per interface		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously active</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> <li>RD_REC</li> <li>WR_REC</li> <li>WR_PARM</li> <li>PARM_MOD</li> <li>WR_DPARM</li> <li>DPNRM_DG</li> <li>RDSYSST</li> <li>DP_TOPOL</li> <li>configuration / programming / number of simultaneously active</li> </ul>	7 Yes see instruction list see instruction list see instruction list Yes Yes Yes Yes Yes Yes SEC / header 2; SFC 11; per interface 8; SFC 2; per interface 8; SFC 59; per interface 8; SFC 59; per interface 8; SFC 56; per interface 8; SFC 57; per interface 8; SFC 57; per interface 8; SFC 13; per interface 8; SFC 13; per interface 8; SFC 103; per interface 8 1; SFC 103; per interface		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously active</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> <li>RD_REC</li> <li>WR_REC</li> <li>WR_PARM</li> <li>PARM_MOD</li> <li>WR_DPARM</li> <li>DPNRM_DG</li> <li>RDSYSST</li> <li>DP_TOPOL</li> <li>configuration / programming / number of simultaneously active</li> </ul>	7 Yes see instruction list see instruction list see instruction list Yes Yes Yes Yes Yes Yes SFC / header 2; SFC 11; per interface 8; SFC 23; per interface 8; SFC 53; per interface 8; SFC 56; per interface 8; SFC 55; per interface 8; SFC 56; per interface 8; SFC 57; per interface 8; SFC 57; per interface 8; SFC 56; per interface 8; SFC 57; per interface 8; SFC 57; per interface 8; SFC 57; per interface 8; SFC 57; per interface 8; SFC 56; per interface 8; SFC 13; per interface 8; SFC 13; per interface 8; SFC 13; per interface 8 5FB / header 8; SFB 52; per interface, but not more than 32 across all external interfaces		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously active</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> <li>RD_REC</li> <li>WR_PARM</li> <li>PARM_MOD</li> <li>WR_DPARM</li> <li>DPNRM_DG</li> <li>RDSYSST</li> <li>DP_TOPOL</li> <li>configuration / programming / number of simultaneously active</li> </ul>	7 Yes see instruction list see instruction list see instruction list Yes Yes Yes Yes Yes Yes SFC / header 2; SFC 11; per interface 8; SFC 29; per interface 8; SFC 59; per interface 8; SFC 59; per interface 8; SFC 56; per interface 8; SFC 56; per interface 8; SFC 57; per interface 8; SFC 56; per interface 8; SFC 56; per interface 8; SFC 13; per interface 8; SFC 13; per interface 8; SFC 103; per interface 8 1; SFC 103; per interface		
<ul> <li>Command set</li> <li>Nesting levels</li> <li>Access to consistent data in process image</li> <li>System functions (SFC)</li> <li>System function blocks (SFB)</li> <li>Programming language <ul> <li>LAD</li> <li>FBD</li> <li>STL</li> <li>SCL</li> <li>CFC</li> <li>GRAPH</li> <li>HiGraph®</li> </ul> </li> <li>configuration / programming / number of simultaneously active</li> <li>DPSYC_FR</li> <li>D_ACT_DP</li> <li>RD_REC</li> <li>WR_REC</li> <li>WR_PARM</li> <li>PARM_MOD</li> <li>WR_DPARM</li> <li>DPNRM_DG</li> <li>RDSYSST</li> <li>DP_TOPOL</li> <li>configuration / programming / number of simultaneously active</li> </ul>	7 Yes see instruction list see instruction list see instruction list Yes Yes Yes Yes Yes Yes SFC / header 2; SFC 11; per interface 8; SFC 23; per interface 8; SFC 53; per interface 8; SFC 56; per interface 8; SFC 55; per interface 8; SFC 56; per interface 8; SFC 57; per interface 8; SFC 57; per interface 8; SFC 56; per interface 8; SFC 57; per interface 8; SFC 57; per interface 8; SFC 57; per interface 8; SFC 57; per interface 8; SFC 56; per interface 8; SFC 13; per interface 8; SFC 13; per interface 8; SFC 13; per interface 8 5FB / header 8; SFB 52; per interface, but not more than 32 across all external interfaces		

Dimensions	
25 mm	
290 mm	
219 mm	
700 g	
	290 mm 219 mm

last modified:

9/11/2023 🖸